

# Detailed Latest Test Results

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 21/03/2013 To: 21/03/2014

Site: DAVES DISCO		Location: HOUSE		
Asset ID:	Description:	User:	Test Instrument:	
86419	LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.026	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86420	IEC MULTIBLOCK	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.14	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86421	LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.142	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86422	LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.136	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86423	LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.136	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86424	LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.14	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86425	EXTENSION LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.27	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				
86426	6 WAY EXTENSION LEAD	J D B	11D-0544	
Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.09	ohm	Pass
IEC Lead Polarity	21/03/2013			Pass
Overall: Pass				

# Detailed Latest Test Results

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 21/03/2013 To: 21/03/2014

Asset ID: 86427	Description: LEAD	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
IEC Lead Continuity	21/03/2013	0.048	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass
IEC Lead Polarity	21/03/2013		Pass

Overall: Pass

Asset ID: 86428	Description: AC ADAPTER	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass

Overall: Pass

Asset ID: 86429	Description: SMOKE MACHINE	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
Earth Continuity	21/03/2013	0.092	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass

Overall: Pass

Asset ID: 86430	Description: LEAD	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
IEC Lead Continuity	21/03/2013	0.064	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass
IEC Lead Polarity	21/03/2013		Pass

Overall: Pass

Asset ID: 86431	Description: PSU	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass

Overall: Pass

Asset ID: 86432	Description: LEAD	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
IEC Lead Continuity	21/03/2013	0.066	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass
IEC Lead Polarity	21/03/2013		Pass

Overall: Pass

Asset ID: 86433	Description: LEAD	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
IEC Lead Continuity	21/03/2013	0.06	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass
IEC Lead Polarity	21/03/2013		Pass

Overall: Pass

Asset ID: 86434	Description: SPEAKER	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
Earth Continuity	21/03/2013	0.068	ohm Pass
Insulation Voltage	21/03/2013	500	V Information
Insulation	21/03/2013	> 199	MOhm Pass

Overall: Pass

Asset ID: 86435	Description: SPEAKER	User: J D B	Test Instrument: 11D-0544
Test Type	Date	Result	Unit Status
Visual	21/03/2013		Pass
Earth Continuity	21/03/2013	0.076	ohm Pass
Insulation Voltage	21/03/2013	500	V Information

# Detailed Latest Test Results

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 21/03/2013 To: 21/03/2014

Insulation 21/03/2013 > 199 MOhm Pass  
Overall: Pass

Asset ID: 86436 Description: SPEAKER User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.046	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86437 Description: LIGHTING RIG User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.06	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86438 Description: LIGHT User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.308	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86439 Description: LIGHT User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.056	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86440 Description: LEAD User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
IEC Lead Continuity	21/03/2013	0.054	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass
IEC Lead Polarity	21/03/2013			Pass

Overall: Pass

Asset ID: 86441 Description: PSU User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86442 Description: SPEAKER User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.11	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Asset ID: 86443 Description: SPEAKER User: J D B Test Instrument: 11D-0544

Test Type	Date	Result	Unit	Status
Visual	21/03/2013			Pass
Earth Continuity	21/03/2013	0.072	ohm	Pass
Insulation Voltage	21/03/2013	500	V	Information
Insulation	21/03/2013	> 199	MOhm	Pass

Overall: Pass

Total Tests: 25